

1	3.8	31	648.1	61	1718.6	91	2923.5	121	4045.8	151	4833.4
2	10.7	32	679.1	62	1757.8	92	2963.5	122	4079.2	152	4849.0
3	19.7	33	710.6	63	1797.2	93	3003.3	123	4112.2	153	4863.5
4	30.4	34	742.4	64	1836.7	94	3043.1	124	4144.8	154	4876.9
5	42.5	35	774.6	65	1876.3	95	3082.7	125	4177.0	155	4889.0
6	55.8	36	807.2	66	1916.1	96	3122.2	126	4208.8	156	4899.6
7	70.4	37	840.2	67	1955.9	97	3161.6	127	4240.3	157	4908.6
8	86.0	38	873.6	68	1995.9	98	3200.8	128	4271.3	158	4915.6
9	102.6	39	907.3	69	2035.9	99	3239.9	129	4301.8	159	4919.4
10	120.1	40	941.3	70	2076.0	100	3278.8	130	4332.0		
11	138.5	41	975.7	71	2116.2	101	3317.6	131	4361.7		
12	157.8	42	1010.4	72	2156.5	102	3356.2	132	4390.9		
13	177.9	43	1045.4	73	2196.8	103	3394.6	133	4419.6		
14	198.7	44	1080.7	74	2237.1	104	3432.9	134	4447.8		
15	220.3	45	1116.3	75	2277.5	105	3470.9	135	4475.5		
16	242.6	46	1152.2	76	2318.0	106	3508.8	136	4502.7		
17	265.6	47	1188.4	77	2358.5	107	3546.4	137	4529.3		
18	289.3	48	1224.8	78	2398.9	108	3583.8	138	4555.4		
19	313.6	49	1261.5	79	2439.4	109	3621.0	139	4580.9		
20	338.5	50	1298.4	80	2479.9	110	3657.9	140	4605.8		
21	364.0	51	1335.6	81	2520.5	111	3694.6	141	4630.1		
22	390.0	52	1373.0	82	2560.9	112	3731.0	142	4653.8		
23	416.7	53	1410.6	83	2601.4	113	3767.2	143	4676.8		
24	443.9	54	1448.5	84	2641.9	114	3803.1	144	4699.1		
25	471.6	55	1486.5	85	2682.3	115	3838.7	145	4720.7		
26	499.8	56	1524.8	86	2722.6	116	3874.0	146	4741.5		
27	528.5	57	1563.2	87	2762.9	117	3909.0	147	4761.6		
28	557.7	58	1601.8	88	2803.2	118	3943.7	148	4780.9		
29	587.4	59	1640.6	89	2843.4	119	3978.1	149	4799.3		
30	617.5	60	1679.5	90	2883.5	120	4012.1	150	4816.8		

Die Peiltabelle wurde rechnerisch ermittelt und ist für amtliche Zwecke nicht geeignet. Aufgrund von unterschiedlichen Einbaubedingungen sowie Toleranzen sind Abweichungen von bis zu 6% möglich.

Erfahrungsgemäß hat die Saugleitung einen Abstand von 5 – 10 cm zum Boden.