

cm	Liter	cm	Liter	cm	Liter	cm	Liter	cm	Liter	cm	Liter
1	5.5	31	918.0	61	2412.9	91	4086.8	121	5650.9	151	6762.0
2	15.4	32	961.5	62	2467.5	92	4142.3	122	5697.6	152	6784.3
3	28.3	33	1005.6	63	2522.2	93	4197.7	123	5743.9	153	6805.1
4	43.6	34	1050.3	64	2577.1	94	4252.9	124	5789.6	154	6824.2
5	60.9	35	1095.5	65	2632.2	95	4308.0	125	5834.8	155	6841.5
6	80.0	36	1141.2	66	2687.4	96	4362.9	126	5879.5	156	6856.8
7	100.8	37	1187.5	67	2742.8	97	4417.7	127	5923.6	157	6869.7
8	123.1	38	1234.2	68	2798.3	98	4472.2	128	5967.1	158	6879.6
9	146.7	39	1281.4	69	2853.9	99	4526.6	129	6010.1	159	6885.1
10	171.7	40	1329.0	70	2909.7	100	4580.8	130	6052.5		
11	198.0	41	1377.1	71	2965.5	101	4634.7	131	6094.2		
12	225.4	42	1425.6	72	3021.4	102	4688.5	132	6135.3		
13	254.0	43	1474.6	73	3077.4	103	4741.9	133	6175.8		
14	283.6	44	1523.9	74	3133.5	104	4795.2	134	6215.6		
15	314.2	45	1573.7	75	3189.6	105	4848.2	135	6254.6		
16	345.9	46	1623.8	76	3245.8	106	4900.9	136	6293.0		
17	378.5	47	1674.3	77	3302.0	107	4953.3	137	6330.6		
18	412.0	48	1725.1	78	3358.2	108	5005.5	138	6367.5		
19	446.4	49	1776.3	79	3414.4	109	5057.3	139	6403.5		
20	481.6	50	1827.8	80	3470.7	110	5108.8	140	6438.7		
21	517.6	51	1879.6	81	3526.9	111	5160.0	141	6473.1		
22	554.5	52	1931.8	82	3583.1	112	5210.8	142	6506.6		
23	592.1	53	1984.2	83	3639.3	113	5261.3	143	6539.2		
24	630.5	54	2036.9	84	3695.5	114	5311.4	144	6570.9		
25	669.5	55	2089.9	85	3751.6	115	5361.2	145	6601.5		
26	709.3	56	2143.2	86	3807.7	116	5410.5	146	6631.1		
27	749.8	57	2196.6	87	3863.7	117	5459.5	147	6659.7		
28	790.9	58	2250.4	88	3919.6	118	5508.0	148	6687.1		
29	832.6	59	2304.3	89	3975.4	119	5556.1	149	6713.4		
30	875.0	60	2358.5	90	4031.2	120	5603.7	150	6738.4		

Die Peiltabelle wurde rechnerisch ermittelt und ist für amtliche Zwecke nicht geeignet. Aufgrund von unterschiedlichen Einbaubedingungen sowie Toleranzen sind Abweichungen von bis zu 6% möglich.

Erfahrungsgemäß hat die Saugleitung einen Abstand von 5 – 10 cm zum Boden.